



GUIDE SPECIFICATION

PTE Extender:

PTE Extender shall have a brass body, EPDM O-ring seal, and shall extend the length of the PT or PTV 1-1/2". Extender shall be able to be field installed without removing the PT or PTV from the pipe or valve. Rated to 500 PSI / 3450 kPa, and 250°F / 120°C.

PTE extender shall be PTV ENTERPRISES Model PTE or approved equal.